

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:35 am

PWS ID: UTAH02015 **Name:** RIVERSIDE-NORTH GARLAND WATER CO
Legal Contact: RIVERSIDE-N GARLAND WTRCO **Rating:** Approved
GARY HUBER **Rating Date:** 05/21/1990
Address: 5620 W 13600 N **Activity Status:** Active
GARLAND, UT 84312
Phone Number: 435-452-2026
City Served (Area):
County: BOX ELDER COUNTY
System Type: Community **Last Inv Update:** 05/18/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/19/2009 **Total Dsgn Cap:**
Population: 750 **Surveyor:** DAVID F HANSEN **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	ANDERSON, CRAIG M		435-257-3617		
AC	HUBER, GARY				

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	327
			327 Total Svc Connections

Storage

Total Storage: 655,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	330 K TANK	Ground	330,000 GAL	Concrete		A	NO
ST002	125 K TANK	Ground	125,000 GAL	Concrete		A	NO
ST003	200 K TANK	Ground	200,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	RIVERSIDE-N GARLAND WTRCO		I	
TP002	WELL #2 CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	12	325 GPM	325 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	Active	WL	16	437 GPM	435 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS003	UTAH02070 BEAR RIVER W	Active	CC				No	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*